

State Level Water Testing Laboratory

PWD(DWS), Government of Tripura
P.N. Complex,
Agartala - 799006
Mobile : 9402120089,
Website : www.dws.tripura.gov.in



TC-7350

TEST REPORT

Name & Address of the customer

Mihir Debbarma. Principal. ,Water
Sample from Taibandal H.S.
School. Sonamura, Sepahijala,
Tripura, Tripura

Report No : SLWTL/2017/6622
Report Date : 06-08-2026
Sample ID : 039Y58D7M4
Date of Receipt of Sample : 29/07/2026, 12.30 pm
Date(s) of Performance : 01/08/2026
Ref. No. & Date : No.F.6(1)/THSS/SNM/CBSE/2022/148 Date-
28/07/2026
ULR No : TC735025000013719F

We hereby certify that the following sample submitted to the laboratory has been analyzed with the following results :

1.	Description of Sample (As declared by customer)	: Drinking Water
2.	Volume of Sample Received	: 500 ml
3.	Sample Mark (if any, given by the customer)	: NA
4.	Date of Sampling by the Customer	: 29/07/2026
5.	Source & Place of Sampling	: Water Sample from Taibandal H.S. School. Sonamura, Sepahijala, Tripura
6.	Environmental conditions during sampling	: NA
7.	Sampling Plan & Procedures used	: NA

Report Prepared by

Signature : 
Name : Ratan Shil
Designation : Technical Manager

For State Level Water Testing Laboratory

Signature : 
Name : Sujoy Paul
Designation : Quality Manager
Authorized Signatory

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced except in full, without the permission of State Level Water Testing Laboratory, PWD(DWS)
- The reserved part of sample(s) shall be retained for 15 days from the date of Completion of Test.

Contact Person : Dr Sujoy Paul,
Quality Manager, State Level Water Testing Laboratory
Mobile : 9402120089, Email : s.manna.paul@gmail.com, Website : www.dws.tripura.gov.in

State Level Water Testing Laboratory

PWD(DWS), Government of Tripura
P.N. Complex,
Agartala - 799006
Mobile : 9402120089,
Website : www.dws.tripura.gov.in



TC-7350

Report No : SLWTL/2017/6622
Sample ID : 039Y58D7M4

Analysis of Result

SN	Characteristic	Acceptable Limit (as per BIS 10500:2012)	Permissible Limit (as per BIS 10500:2012)	Method of Test	Results
1	Turbidity in N.T.U	1	5	APHA 24th Edition 2130 B	0.77
2	pH value at 25°C	6.5-8.5	No Relaxation	APHA 24th Edition 4500-H+ B	7.22
3	Iron (as Fe) in mg/l	1.0	No Relaxation	APHA 24th Edition 3500-Fe B	0.074
4	Total Dissolved Solids in mg/l	500	2000	APHA 24th Edition 2540 C	45.6

BDL - Below Detection Level for Fluoride - <0.2 mg/l, Arsenic - <0.009 mg/l, Iron - <0.1 mg/l, Magnesium - <2 mg/l, Manganese - <0.01 mg/l

Report Prepared by

Signature

Name : Ratan Shil

Designation : Technical Manager

For State Level Water Testing Laboratory

Signature

Name : Sujoy Paul

Designation : Quality Manager

Authorized Signatory

-: End Of Report :-

Contact Person : Dr Sujoy Paul

Quality Manager, State Level Water Testing Laboratory.

Mobile : 9402120089, Email : s.manna.paul@gmail.com, Website : www.dws.tripura.gov.in

Government of Tripura
Office of the Medical Officer In-charge
Taibandal PHC
Sonamura, Sepahijala, Tripura-799105

No. F1(80)/TBL/PHC/MOIC/OC/2025-26

Date: 28/08/2026

HEALTH AND SANITATION CERTIFICATE

This is to certify that an inspection team from Taibandal Primary Health Centre (PHC) visited and inspected the school campus, classrooms, water supply systems, kitchen hygiene and sanitary installations of **Taibandal H.S. School**, situated at North Taibandal, Sonamura, Sepahijala District, Tripura, in response to their application dated 27/08/2026.

During the inspection, it was observed that the school maintains clean and safe drinking water facilities for its students and staff members. The school campus, washrooms, and surrounding premises are well-maintained, hygienic, and compliant with acceptable health and sanitation standards.

Hence, the school campus is declared to fit the overall health, hygienic, and sanitary conditions required under prevailing regulatory guidelines. This certificate is issued to facilitate the school's application process for **CBSE re-affiliation**.

This certificate is valid for a period of one (1) year from the date of issue, subject to the maintenance of the same standards throughout the period.


28/8/2026
Medical Officer In-charge
Taibandal PHC
Sonamura, Sepahijala, Tripura.
Medical Officer In-Charge
Taibandal PHC
Sonamura, Sepahijala, Tripura